



Jim Doyle, Governor
Mary P. Burke, Secretary

October 19, 2005

POLYLOK, INC
PATRICK MULHALL
4003 CAPITAL DR
WALLINGFORD CT 06492

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)
Manufacturer: POLYLOK, INC
Product Name: EFFLUENT FILTER
Model Number(s): 3014-525 and 3014-625
Product File No: 20050761

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2010.

This approval supersedes the approval issued on December 21, 2004, under product file number 20040612.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040612.

This approval is contingent upon compliance with the following stipulation(s):

- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.
- Model 3014-525 will prevent solids with a size greater than 1/16" in size from passing and model 3014-625 will prevent solids with a size greater than 1/32" in size from passing.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mbeckwith@commerce.state.wi.us